

ADDENDUM B, May 30, 2024

RE: Washington Unified School District
ESSR III Projects
DSA File No. 57-31 and 57-H5
DSA Application Nos. 02-122273, 02-122274, 02-122276, 02-122277, 02-122278, 02-122279, 02-122280
and 02-122281
Studio W Project Numbers 22040, 22042, 22043, 22044, 22046, 22047, 22048 and 22049

From: Studio W Architects
1930 H Street, Sacramento, CA 95811

To: Prospective Bidders

This Addendum forms a part of the Contract Documents and modifies the original bidding documents DSA approved on March 19, 2024, March 21, 2024, March 26, 2024 and May 3, 2024, as noted below. Acknowledge receipt of this Addendum in the space provided on the Bid Form. Failure to do so may subject Bidder to disqualification.

The following changes or clarifications shall be made part of the Bid Documents and shall be taken into consideration when submitting bids.

Bidder's Questions:

1. Clarification of Bidder Question #7 from Addendum A, the Poured-In Place Playground Surfacing is to be per the plans and details calling for a 3" SBR cushion and 0.5" Wear Course (3.5" system).

Attachments:

None

END OF ADDENDUM B

Distribution: WUSD
Studio W Project File 22040, 22042, 22043, 22044, 22046, 22047, 22048, and 22049
Division of the State Architect

Note: It is incumbent upon the Prime Bidder to notify his subcontractor and/or materials supplier of the above changes in the Contract Documents.

For: 930 Westacre Road, West Sacramento, CA 95691

Studio W Architects
980 9th Street, Suite 2050, Sacramento, CA 95814
(916) 254-5600



Brian P. Whitmore, AIA

C30345

STATE OF CALIFORNIA – DIVISION OF THE STATE ARCHITECT

